

Proposed Code Change State Form 41186R

RETURN TO: INDIANA DEPARTMENT OF HOMELAND SECURITY CODE SERVICES SECTION 302 W. Washington Street Room W246

Indianapolis, IN 46204

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY - Dashed line through material to be deleted, underline material to be added)

FOR OFFICE USE ONLY

Received 5/12/09

Code 49-09

Use second sheet for any material requiring more space.						
Code Title	Edition					
IRC						
Section number and title		Page				
R408.3 Unvented Crawl Space		108				
Proponent	Title					
Jeff Washler						
Address		Phone				
3435 CR 52, Auburn, IN 46706		260.925.8427				
PROPOSED CODE CHANGE (Check One)						
Add Exception 6 from 2003 code to read as: "2.4 Ventilation openings are not required when the under floor space is insulated in accordance with Chapter 11 of this code, the insulation materials comply with sections R314 and R316 of this code and ground surface is covered with an approved vapor retarder that extends to the exterior walls and all penetrations. The vapor retarder shall have a minimum thickness of 0.006 inch and shall be installed so that any joints are lapped at least 6 inches. Mechanical ductwork shall be uninsulated and shall not have any openings into the under floor space. A hard surface pad of at least 16x16 inches and an electrical receptacle shall be installed to allow for the installation of dehumidification equipment in case of high humidity in the under floor space, Openings into conditioned space shall be permitted."						
REASON AND FISCAL IMPACT						
This exception has been used in the past with success. Fiscal impact shouldn't be any different from 2003 code						
,						
REVIEW RECOMMENDATION						
Approve						
Disapprove						
Approve as amended						
Further Study						